



REV	DATE	DESCRIPTION	BY	CHKD	APPD
1	08/01/2016	ISSUED FOR CUSTOMER REVIEW	WDT	WDT	WDT
2	08/01/2016	REVISED FOR PRODUCTION RELEASE	WDT	WDT	WDT
3	08/23/2016	REVISED AS NOTED	WDT	WDT	WDT

CUSTOMER		ATLANTIC ODA		THIRD-ANGLE PROJECTION	
REFERENCE:	DATE:	PROJECT NO.:	DATE:	REVISION:	
PROJECT NO.:	DATE:	PROJECT NO.:	DATE:	REVISION:	
<small>NOTICE TO PERSONS RECEIVING THIS DRAWING: PITCHARD-BROWN FLA, INC. OF ENGINEERING, DESIGN, AND CONSTRUCTION SERVICES, INC. CLAIMS PROTECTED BY PATENT. THE INFORMATION CONTAINED HEREIN IS UNCLASSIFIED EXCEPT WHERE SHOWN OTHERWISE. IT IS CLASSIFIED FOR PROTECTION ONLY AND MAY NOT BE REPRODUCED OR USED TO INFRINGE ANY PATENT RIGHTS OR OTHER RIGHTS HEREON WITHOUT PERMISSION FROM PITCHARD-BROWN FLA, INC.</small>					
PITCHARD-BROWN FLA, INC.		2960 COUNTY ROAD 541 TAMPAH, FL 33676			
ELECTRICAL ONE LINE (3 PHASE)					
DATE:	SCALE:	JOB SERIAL NO.:	F011064/65		
APP:	SCALE:	APP:	SHEET:	OF:	

- LEGEND:**
- CCB - CUSTOMER CONNECTION BOX
 - LFALC - LOW FUEL LEVEL ALARM CONTACTS
 - HFALC - HIGH FUEL LEVEL ALARM CONTACTS
 - RUFUSE - FUSE
 - RUPULSE - FUSE
 - LBV - LOW BATTERY VOLTAGE CONTACTS
 - HBV - HIGH BATTERY VOLTAGE CONTACTS
 - CHG.FAL - BATTERY CHARGER FAL ALARM CONTACTS
 - ADC - AUX DISCONNECT
 - BR - RUN RELAY
 - ACC - ACCURATE CURRENT
 - DC - DIRECT CURRENT
 - WIRING BY OTHERS
- * NOTES:**
- LOADS ARE SPRING OPEN / MOTOR CLOSE
 - AUX RUN RELAY LOCATED IN ENGINE CONTROL PANEL UNLESS OTHERWISE NOTED
 - FUSE LOCATED IN CCB UNLESS SUPPLIED JUNCTION BOX

E
D
C
B
A

8
7
6
5
4
3
2
1

* ALL WIRING IN SURFACE MOUNTED EMT

SEE DIGITAL FUEL GAUGE SHEET

