



REV	DATE	DESCRIPTION	BY	APP'D
A	08/24/2017	ISSUED PER CUSTOMER REQUEST	DAVE	DAVE
B	08/24/2017	REVISED FOR PRODUCTION RELEASE	DAVE	DAVE
C	08/24/2017	REVISED AS NOTED	DAVE	DAVE

**NOTES**

- 1 THE 1KΩ RESISTOR PROTECTS FROM SURGES. A BLOWN FUSE MAY INDICATE THE 1KΩ RESISTOR NEEDS TO BE REPLACED.
- 2 INSTALL THE SENDER SO THAT THE PROBE IS 1" FROM THE BOTTOM OF THE TANK. AN OPTIONAL WATERSCREEN WILL BE INSTALLED 1/2" FROM THE BOTTOM.
- 3 FINE ADJUSTMENTS CAN BE MADE BY CENTER TURNING THE FULL POST ON TOP OF THE SENDER UNTIL THE DESIRED READING IS ACHIEVED.

CUSTOMER		ATLANTIC ODA	
REFERENCE	DATE	THIRD-ANGLE PROJECTION	
PROJECT NO.	DATE	REVISION	
PROJECT NO. 2001100		C	
NOTICE TO PERSONS RECEIVING THIS DRAWING: PRITCHARD-BROWN DIV. OF ENVIRO INDUSTRIES, INC. CLAIMS PROTECTED BY PATENT IN THE UNITED STATES AND ABROAD. THIS DRAWING IS ISSUED FOR SALES INFORMATION ONLY AND MAY NOT BE REPRODUCED OR USED TO FABRICATE ANYTHING OTHER HEREON WITHOUT PERMISSION FROM PRITCHARD-BROWN DIV. OF		DATE 08/23/17	
PRITCHARD-BROWN DIV. OF ENVIRO INDUSTRIES, INC.		4650 EISENHART AVE. BALTIMORE, MD 21286	
STD DIGITAL FUEL GAUGE w/ AUDIBLE ALARM			
DRW	REV	JOB SERIAL NO.	F011064/65
CHK	REV		
APP	REV		
APP	REV	SCALE	SHEET 1 OF 1

COMPUTER GENERATED